

## Approved Electric Submeters, COMAR 20.25.01.04A.(3)

Manufacturer	Type Number	Current Transformer
ABB, Elster	ABS-5, REX-5, AB1, A1D, A1T+, A1RL	
ADEC	EMS-8000	
Austin International, Inc.	Vision Watthour Meter V2S, V2SR, V12S, V12SR, V1S, V1SR	
Duncan	MK, MQ, MH2, MG2, JH2A, MS, MS-1, 12S, MTNS12S, 16S	
E-Mon Corporation	E-MON D-MON Electronic KWH Model 208100	Not applicable
General Electric	130, I50S, I55S, I60 S I-70 watt-hour <sup>1</sup> I70S/A, IM70S/A, IW70S/A, I70S/1, I70S/2 KVS, KV-3PH, KV2, KV2C V 3A,6A,62,65,66,612S, EV, VM-3A,4A,63,64 i210, i210+C, IM70S	
Global Power Products (formerly North American Power Products)	VT-2 solid state meter	Not applicable
Integrated Metering Systems, Inc.	MMD1202001-SCC MMD1202001 Blue Series 3 phase	CT200148BKSO-0.72 CT200148RDSO-0.72 CT200148BLSO-0.72 CT200148BKSO-0.67 CT200148RDSO-0.67 CT200148BLSO-0.67
Intellimeter Canada Inc.	TX120X00X TX120-X2X	100A, CTR 2500:1A, Internal PCB Mounted 200A, CTR 2000:1A; externally mounted
Landis & Gyr	MS2, MSK, MTNS, MR2S, ML2S, DX MS, MS, MSE, MX, Focus: ALF, AXS4, AXS4e, AXR, AXRSD	
Sangamo	S-12-S, J5S watt-hour Class 200, 240v	
Schlumberger	Centron: C1S and CN1S models	

<sup>1</sup> General Electric Type I-70 with a cyclometer register is not recommended for use.

	(all), Centron Polyphase, Sentinel, J, J2S, J3S, J4S, J5S, SL5S S12S, SL12S, Vectron: SV2S, P20S, P20SU,	
Sensus	iCon, iConA	
Siemens / L&G	Altimus: AX, AL, ALT	
QUADLOGIC	S-20 Socket Meter S-10 In-unit Residential Meter RSM 5 Commercial Meter Minicloset 5 Multi-tenet Meter Minicloset 5c Multi-tenet Meter	
Technology Research Corp.	18020-001 <sup>2</sup> , 2-element 120/208 VAC 2 Ø or 120/240 VAC 1 Ø 3-wire, 60HZ with electromechanical counter	200 amp primary max. <sup>3</sup> 0.2 amp secondary max.
United Metering Services (UMS)	Electronic watt-hour <sup>4</sup> meter with electromechanical counter, P/N 22120E, 120/208/240 VAC, 2-element	200 amp primary max. <sup>5</sup> 0.2 amp secondary
Westinghouse	D4S3, D5S3, D4S5U, D2S, C, D, CS, D4S, D4-1 D5S, D5S Network	

---

Morris Schriem  
Chief Engineer

---

<sup>2</sup> A current transformer type metering device shall not be used in Maryland unless the current transformer used in conjunction therewith meets all requirements specified in IEEE C57.13, Standard Requirements for Instrument Transformers.

<sup>3</sup> The TRC watt-hour meter may be used only for indoor installation, because the cover of the meter is not rain-tight.

<sup>4</sup> The current transformers (current sensors) should be installed in a steel, rust-resistant enclosure to prevent unauthorized access to them.

<sup>5</sup> The UMS watt-hour meter is intended for indoor use only.